

R10 Specification Clauses

Product	"Sentinel" Vintage Ogee "Snap Fit" Gutter System
Manufacturer	ARP Ltd Unit 2, Vitruvius Way Meridian Business Park Braunstone Leicester LE19 1WA ph. 0116 289 4400 Web. www.arp-ltd.com
Specification	"Sentinel" Vintage Ogee "Snap Fit" Gutter System Manufactured from Aluminium Alloy 6063 T6 to BS1474: 1972 Size - 125 x 100mm or 150 x 100mm (delete where applicable)
Finish	Mill Finish Aluminium or Polyester Powder Coated to RAL_____ or BS_____ (delete where applicable) Materials to have factory applied Polyester Powder Coat to all significant surfaces
Fitting (brackets)	Gutter to be fitted on "Sentinel" Brackets at 750mm centres with an additional bracket required for all Running Outlets and Angles no further than 375mm from joint. Brackets to be Fascia or Rafter Top-Fix or Rafter Side-Fix or Rise and Fall (delete where applicable) Expansion gaps of 3-4mm to be left between butt ends
or (Direct fix)	Gutter to be secured via predrilled holes at 750mm centres with 5 x 25mm stainless steel countersunk screws (dependant on substrate) Angles to be secured via the two predrilled holes on rear with 5 x 25mm stainless steel countersunk screws (dependant on substrate) Outlets to be via the predrilled hole in rear with 5 x 25mm stainless steel countersunk screws (dependant on substrate) Expansion gaps of 3-4mm to be left between butt ends
Outlets	Outlets to suit Ø63mm or 76mm or 101mm Circular or 63mm or 76mm or 101mm Square or 101x76mm Rectangular "Colonnade" downpipes (delete where applicable)
Jointing	Joints to be made with "Sentinel Snap Fit" Union Connectors and Arbosil 1096 Low Modulus Sealant Full fitting instructions to be supplied with delivery